

## **CERTIFICATE**

CEIS, centro de ensayos, innovación y servicios, **CERTIFIES:**


- That CEIS has installed several times two split air conditioners delivered with quick connections, with the following references:

Brand of the air conditioners: Zibro

Brand Coupling	Coupling model reference	Description
Parker Hannifin Corporation USA	RC04-A01-6666	(Coupling Male half, outdoor unit)
Parker Hannifin Corporation USA	RC04-B02-6666	(Coupling Female half, indoor unit refrigerant line)

- That during these installations, no refrigerant leakage has been observed.
- That in our opinion, the air conditioners using this type of quick connections can be installed by the end user without any risk for the environment.

Móstoles, 26 July 2007



André Pierrot  
Head of the heat pump laboratory